

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION DECLARATION

Date: 26.06.2025

_____ (Name of the Officer with designation) from
_____ GSF, COSSIPORE _____ (Name of department/ office) inspected the
_____ GSF HIGH SCHOOL, COSSIPORE _____ (Name and address of
the School _____ 26.06.2025 _____ and found that _____ GSF HIGH SCHOOL, COSSIPORE
_____ (Name of School) has safe drinking water facilities for the student and member of staff of the
institution and is maintaining the hygienic sanitation condition in the School building and the campus as
per the norms prescribed by the Central/ State/U.T. Govt.

Signature with seal

Designation JWM(SG)/GSF

THE PRINCIPAL _____

GSF HIGH SCHOOL, COSSIPORE

(Name and address of the institution)

रमन चौधुरी / RAMEN CHOUDHURI
 ज्य. कार्य प्रबन्धक / Jr. Works Manager
 भारत सरकार / Govt. of India
 रक्षा मंत्रालय / Mins. of Defence
 तोप एवं गोला निर्माण / Gun & Shell Factory
 कोसपूर, कोलकाता-२ / Cossipore, Kolkata-2



TEST REPORT

Name & Address Of the Customer :	UIR No.	: TC627125000002652F
M. S. Gas & Shell Factory	Report No.	: QLS/P-15/25-26/C/25
(A unit of AWEIL)	Date	: 18.06.2025
Cossipur,	Sample No.	: QLS/P-15/25-26/25
Kolkata - 700 002	Sample Description	: Drinking Water
	Sample Mark/Location	: W-II Pump House outside the Factory
	Date of Performance(s)	: 14.06.2025-18.06.2025
	Sample Submitted On	: 13.06.2025
	Sampling Method	: IS 17614(P-25) 2021
	Ref No. & Date	: Verbal Confirmation

Analysis Result

Sl. No.	Characteristic	Limit as per Drinking Water Standard : IS:10500, 2012, (RA 2018) Amd-2	Test Method	Result
1.	Total Coliform Bacteria/100ml	Not Detectable	IS 15185-2016 (RA 2021)	Not Detected
2.	E.Coli/100ml	Not Detectable	IS 15185-2016 (RA 2021)	Not Detected
3.	Faecal Coliform/100ml	----	IS 1622:1981 (RA:2019)	<2
4.	Odour	Agreeable	IS 3025(Part 5)-2018	Agreeable

Report Prepared By:

for Qualissure Laboratory Services
Reviewed & Authorized By

S. Chakraborty
Soumy Chakraborty, Microbiologist
(Authorized Signatory)

for Qualissure Laboratory Services
Reviewed & Authorized By

Bishnupriya Banerjee
Bishnupriya Banerjee, Chemist
(Authorized Signatory)

-----End of the Report-----

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced without the permission of Qualissure Laboratory Services.
- The reserved part of sample(s), except perishable sample(s), shall be retained for 30 days from the date of issue of the Test Report.



TC-6271

DOC NO : QLS/SAMP/03-0/00

TEST REPORT

Name & Address Of the Customer :	ULR No.	TC627125000002430F
M/s. Gun & Shell Factory (A unit of AWEIL)	Report No.	QLS/P-15/25-26/C/21
Cossipur,	Date	09.06.2025
Kolkata – 700 002	Sample No.	QLS/P-15/25-26/21
	Sample Description	Drinking Water
	Sample Mark/Location	Industrial Canteen Inside the Factory CSF
	Sample Drawn On	28.05.2025
	Date of Performance(s)	29.05.2025-07.06.2025
	Sampling Method	IS 17614(P-5 & P-25) 2021 & 2022
	Ref No. & Date	C.P.O No.250325GP Dated :16.05.2025

Analysis Result

Sl. No.	Test Parameter	Test Method	As per Drinking Water Standard: IS:10500, 2012Amd. No. 1 & 2		Result
			Acceptable Limit	Permissible Limit	
1	pH Value at 25°C	IS 3025 (Part 11)- 2022	6.5-8.5	No Relaxation	7.26
2	Taste	IS 3025 (Part 7 & 8): 2023	Agreeable	Agreeable	Agreeable
3	Turbidity in NTU	IS 3025 (Part 10)- 2023	1	5	<1
4	Calcium (as Ca) in mg/l	IS 3025 (Part 40): 1991(RA 2019)	75	200	26.9
5	Chloride (as Cl) in mg/l	IS 3025 (Part 32)-1988, (RA: 2019)	250	1000	36.0
6	Iron (as Fe) in mg/l	IS 3025(Part 53)-2003 (RA: 2019)	1.0	No Relaxation	0.15
7	Arsenic (as As) in mg/l	IS 3025 (Part 37): 2022	0.01	0.05	<0.01
8	Nitrate (as NO ₃) in mg/l	IS 3025 (Part 34)-1986 (RA: 2019)	45	No Relaxation	<0.5
9	Magnesium (as Mg) in mg/l	APHA 24 th Edition, 2023; 3500Mg B	30	100	11.4
10	Total Dissolved Solids (TDS) in mg/l	IS 3025(Part 16)- 2022	500	2000	172
11	Alkalinity (as CaCO ₃) in mg/l	IS 3025 (Part 23)- 2023	200	600	120.0
12	Total Hardness (as CaCO ₃) in mg/l	IS 3025 (Part 21)- 2009 (RA: 2019)	200	600	114.3
13	Sulphate (as SO ₄) in mg/l	IS 3025 (Part 24): Sec 1, 2022	200	400	17.4
14	Total Chromium (as Cr) in mg/l	IS 3025 (Part 52): 2003(RA 2019)	0.05	No Relaxation	<0.05
15	Mercury (as Hg) in mg/l	IS 3025 (Part 48): 1994(RA 2019)	0.001	No Relaxation	<0.001

Report Prepared By :

for Qualissure Laboratory Services
Reviewed & Authorized by

Bishnupriya Banerjee, Chemist
(Authorized Signatory)

---End of the Report---

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced without the permission of Qualissure Laboratory Services.
- The retained part of sample(s) except perishable sample(s) shall be retained for 30 days from the date of issue of the Test Report.



TC-6271

DOC NO : QLS/SAM12/08-D/00

TEST REPORT

Name & Address Of the Customer : M/s. Gun & Shell Factory (A unit of AWEIL) Cossipur, Kolkata – 700 002	ULR No.	: TC627125000002653F
	Report No.	: QLS/P-15/25-26/C/26
	Date	: 18.06.2025
	Sample No.	: QLS/P-15/25-26/26
	Sample Description	: Drinking Water
	Sample Mark/Location	: STE Pump House
	Date of Performance(s)	: 14.06.2025-18.06.2025
	Sample Submitted On	: 13.06.2025
	Sampling Method	: IS 17614(P-25) 2021
	Ref No. & Date	: Verbal Confirmation

Analysis Result

Sl. No.	Characteristic	Limit as per Drinking Water Standard : IS:10500, 2012, (RA 2018) Amd-2	Test Method	Result
1.	Total Coliform Bacteria/100ml	Not Detectable	IS 15185-2016 (RA 2021)	Not Detected
2.	E.Coli/100ml	Not Detectable	IS 15185-2016 (RA 2021)	Not Detected
3.	Faecal Coliform/100ml	---	IS 1622:1981 (RA:2019)	<2
4.	Odour	Agreeable	IS 3025(Part 5)-2018	Agreeable

Report Prepared By:

for Qualissure Laboratory Services
Reviewed & Authorized By

Soumy Chakraborty, Microbiologist
(Authorized Signatory)

for Qualissure Laboratory Services
Reviewed & Authorized By

Bishnupriya Banerjee, Chemist
(Authorized Signatory)

-----End of the Report-----

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced without the permission of Qualissure Laboratory Services.
- The reserved part of sample(s), except perishable sample(s), shall be retained for 30 days from the date of issue of the Test Report.